

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631578

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-06

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 12.00x8.00

Primary Air Flow Rate, CFM : 400

Minimum Operating Pressure, in H2O : 0.05

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 58
250 Hz	: 53
500 Hz	: 49
1000 Hz	: 44
2000 Hz	: 41
4000 Hz	: 36

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 67
250 Hz	: 64
500 Hz	: 60
1000 Hz	: 53
2000 Hz	: 49
4000 Hz	: 49

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

**CERTIFICATE NO.:**

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968325077769928

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631579

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-08

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 12.00x10.00

Primary Air Flow Rate, CFM : 700

Minimum Operating Pressure, in H2O : 0.05

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 57
250 Hz	: 54
500 Hz	: 53
1000 Hz	: 45
2000 Hz	: 42
4000 Hz	: 36

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 71
250 Hz	: 71
500 Hz	: 63
1000 Hz	: 59
2000 Hz	: 58
4000 Hz	: 60

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968325594340141



# Certificate of Product Ratings

AHRI Certified Reference Number : 204631580

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-10

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 14.00x12.50

Primary Air Flow Rate, CFM : 1100

Minimum Operating Pressure, in H<sub>2</sub>O : 0.05

Radiated Sound Power Level @ 1.5 in H<sub>2</sub>O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 63
250 Hz	: 59
500 Hz	: 54
1000 Hz	: 47
2000 Hz	: 39
4000 Hz	: 32

Discharge Sound Power Level @ 1.5 in H<sub>2</sub>O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 73
250 Hz	: 70
500 Hz	: 65
1000 Hz	: 60
2000 Hz	: 56
4000 Hz	: 53



†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

## DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

## TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

## CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:



we make life better™

132968325658559735

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631581

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-12

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 16.00x15.00

Primary Air Flow Rate, CFM : 1600

Minimum Operating Pressure, in H2O : 0.05

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 66
250 Hz	: 62
500 Hz	: 54
1000 Hz	: 46
2000 Hz	: 40
4000 Hz	: 36

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 68
250 Hz	: 67
500 Hz	: 62
1000 Hz	: 60
2000 Hz	: 59
4000 Hz	: 57

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968325718716934

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631582

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-14

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 20.00x17.50

Primary Air Flow Rate, CFM : 2100

Minimum Operating Pressure, in H2O : 0.03

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 62
250 Hz	: 57
500 Hz	: 55
1000 Hz	: 45
2000 Hz	: 40
4000 Hz	: 34

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 72
250 Hz	: 69
500 Hz	: 66
1000 Hz	: 61
2000 Hz	: 59
4000 Hz	: 58

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968325819187151

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631584

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-22

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 30.00x23.10

Primary Air Flow Rate, CFM : 5300

Minimum Operating Pressure, in H2O : 0.03

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 76
250 Hz	: 71
500 Hz	: 71
1000 Hz	: 65
2000 Hz	: 60
4000 Hz	: 54

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 86
250 Hz	: 85
500 Hz	: 81
1000 Hz	: 77
2000 Hz	: 74
4000 Hz	: 71

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968327052642978

# Certificate of Product Ratings

AHRI Certified Reference Number : 204631584

Date : 05-12-2022

Model Status : Active

Old AHRI Reference Number :

Brand Name : Galloway

Model Number : PI-VAV-22

Product Type : Single Duct Terminal Unit (Supply)

Country Of Origin : India, Qatar, United Arab Emirates

Rated as follows in accordance with the latest edition of ANSI/AHRI 880 (I-P) with Addendum 1: Performance Rating of Air Terminals and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Rated Duct Width x Height, in : 30.00x23.10

Primary Air Flow Rate, CFM : 5300

Minimum Operating Pressure, in H2O : 0.03

Radiated Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 76
250 Hz	: 71
500 Hz	: 71
1000 Hz	: 65
2000 Hz	: 60
4000 Hz	: 54

Discharge Sound Power Level @ 1.5 in H2O Differential

Static Pressure and 100% Rated Airflow, db

125 Hz	: 86
250 Hz	: 85
500 Hz	: 81
1000 Hz	: 77
2000 Hz	: 74
4000 Hz	: 71

**AHRI** CERTIFIED®  
www.ahridirectory.org

†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced."Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

#### DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

#### TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

#### CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2022 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.:

**AHRI**  
AIR-CONDITIONING, HEATING,  
& REFRIGERATION INSTITUTE

we make life better™

132968327220770427